

29/03/04 44-863

See 4th 1/2 mi, R 3E

July 29, 1971

Hammond Collier & Wade
Litho Stone Corp.
Seattle, Wa. 98107

230' W; 1100' N of E^{1/4} cor.

Well Log For Town Of Langley
Started 6/21/71 Well No. 5, Collier Road, G. L. Collier
Finished 7/18/71

0'-25': Brown silty sand and gravel (or bedrock 10'-25')
25'-35': Very fine blue gray sand
35'-45': Fine blue gray sandy silt
45'-55': Blue sandy silt
55'-65': Blue gray silt
65'-75': Blue sandy silt
75'-125': Blue water bearing sand and gravel (not very pervious)
125'-135': Medium to coarse water bearing sand (pervious)
135'-145': Fine silty water bearing sand (not very pervious)
145'-155': Clean coarse water bearing sand and gravel (very pervious)
155'-175': Clean coarse water bearing sand and gravel pipe 275'-300'
Developed and test pumped.

Test Pump Data

Starting 158'-3"

Pumping at 290 g.p.m. after 3 hrs. 168'-3"

Pumping at 650 g.p.m. after 1 hr. 171'-6"

Recovered to 158'-3" in 30 min.

R 32904-333-460
AGA 837